

CERTIFICATE OF CONFORMITY – Electrical Enclosures

We certify that the MODEL and PRODUCTS listed below have been manufactured in accordance with Quality Management System procedures to meet the requirements of relevant STANDARDS and the requirements of the listed PROTECTION RATING.

MODEL:

SS1 – Wall Mounted Electrical Enclosures, Stainless Steel

PRODUCTS:

IP-SS302015 IP-SS302515 IP-SS303015 IP-SS303020 IP-SS403015 IP-SS403020
IP-SS403025 IP-SS404020 IP-SS404025 IP-SS404030 IP-SS503015 IP-SS503020
IP-SS504020 IP-SS504025 IP-SS505020 IP-SS505025 IP-SS505030 IP-SS604020
IP-SS604025 IP-SS604030 IP-SS606020 IP-SS606030 IP-SS606040 IP-SS705020
IP-SS705025 IP-SS804030 IP-SS806020 IP-SS806025 IP-SS806030 IP-SS806040
IP-SS808020 IP-SS808030 IP-SS808040 IP-SS1006025 IP-SS1006030 IP-SS1008030
IP-SS1008040 IP-SS1206030 IP-SS1208030 IP-SS1208040 IP-SSL304015 IP-SSL304020
IP-SSL406020 IP-SSL406030 IP-SSL608030 IP-304-302015 IP-304-302515 IP-304-303015
IP-304-303020 IP-304-403015 IP-304-403020 IP-304-403025 IP-304-404020 IP-304-404025
IP-304-404030 IP-304-503015 IP-304-503020 IP-304-504020 IP-304-504025 IP-304-505020
IP-304-505025 IP-304-505030 IP-304-604020 IP-304-604025 IP-304-604030 IP-304-606020
IP-304-606030 IP-304-606040 IP-304-705020 IP-304-705025 IP-304-804030 IP-304-806020
IP-304-806025 IP-304-806030 IP-304-806040 IP-304-808020 IP-304-808030 IP-304-808040

STANDARDS (& CONFORMITIES):

IEC/EN 60529, IEC/EN 62208, IEC/EN 61439, CE, UKCA

PROTECTION RATING:

IP66, IK10

CERTIFICATES:

IEC 60529 Degrees of protection provided by enclosures: Certificate AB-0386-T 1902.14 02/00

IEC/EN 62208 Empty Enclosures for low-voltage switchgear and controlgear assemblies: Certificate 0366932-TSE-01/01

IEC/EN61439-1, 61439-2 Low voltage switchgear and controlgear assemblies: Certificate AB-0341-T, 23-297-R1-N1-1

CE Certificate of Compliance: Certificate SZL-21 MA 13338-1

UKCA Certificate of Compliance: Certificate SZU-22MA19560-1

UL: Listing Number E534557

Products are manufactured to Quality, Safety and Environmental standards. In the event that any amendments or modifications to the product or assembly are not explicitly agreed with us, this Certificate of Conformity shall be invalidated.

IP ENCLOSURES PTY LTD

Revision: August 20, 2024