



www.testla.com.tr

## TESTLA

Elektrik Laboratuvarları Tic. Ltd. Şti.

Kuzuluk Mah. Ankara Cad. No:34

Akyazı / SAKARYA TÜRKİYE

+90 264 437 97 70

laboratuvar@testla.com.tr



Test  
TS EN ISO/IEC 17025  
AB-0386-T

AB-0386-T

2009.33.02/00

09.03.2021

### TEST REPORT

Client Name/Address	<b>IP ENCLOSURES PTY. LTD.</b> 19-27 Fred Chaplin Circuit, Bells Creek, QLD, 4551, Australia P: 1300 876 722 ABN: 94 168 980 854		
Name and Identity of Test Item	RECESSED DOOR FIELD CABINET		
Order No.	<b>2009.33</b>	Sample Acceptance Date	<b>05.03.2021</b>
Num. Of Pages of The Report	8 + 1 pages of annexes 9 pages in total	Test Date(s)	<b>09.03.2021</b>
Test Standard(s) Rating(s)	IEC 60529: 04.03.1997 Clause: 13, 14.2.6 IP66 <i>Detail(s) is/are given at the page 3</i>		
Test Result(s)	<b>POSITIVE / Details, are given on the following pages which are part of this report.</b>		

#### Remarks

TESTLA Elektrik Laboratuvarları accredited by TÜRKAK under registration number AB-0386-T for TS EN ISO/TS EN 17025:2017 as test laboratory.

Turkish Accreditation Agency (TURKAK) is a signatory to the European co-operation for Accreditation (EA) Multilateral Agreement (MLA) and to the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA) for the recognition of test reports.

The test and/or measurement results, the uncertainties (if applicable) with confidence probability and test methods are given on the following pages which are part of this report.

Seal

Date

Person in Charge of Test

Approval  
Date



09.03.2021

Mehmet ŞUMNU

2021.03.  
10  
16:01:04  
+03'00'

Caner EREN  
Laboratory Manager

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature is not valid.

Date format: dd.mm.yyyy